FLOOR SLIP RESISTANCE TESTING CERTIFICATE

Testing Certificate Ref No: - **AW/FS/2103002**

Client	**Premier Paper Group Ltd**
Location	**++Sample++**
Date Tested	**09th March 2021**
Pendulum Equipment Used	**KSS Pendulum**
Pendulum Serial No	**ST13**
Pendulum Calibrated	**20th November 2020**
Slider Type Used	**96 Slider**
Slider Ser No(s) - Batch	**96#72**
Slider Date Expiry	**12th April 2021**

The Pendulum was used in accordance with the United Kingdom Slip Resistance Group (UKSRG) guidelines for testing floors to ascertain the slip resistance to BS EN 14231. The tests were carried out under: -

- Wet conditions (Using potable water to cover the whole test area and refreshed between tests).
- Dry conditions

Eight measurements were taken at each condition and in three different horizontal planes (0, 45 and 90 degrees) at each position. The first three measurements were discarded to allow checks for slider stabilisation. The median (average) of the remaining results were then calculated, as advocated by the UKSRG/Health & Safety Executive (HSE). The results for the floors tested are indicated in the table below:

The HSE / UKRSG has determined a minimum Pendulum Test Value reading of 36 must be obtained in all conditions (Dry, Wet, or Contaminated) and on a level surface for a floor to pass the test

Ref	Area/Room	Surface	Ambient Temp (deg C)	Mean (Average) Reading	Pass / Fail
1	Sample	ETEC Floor & Decor	22c	**DRY 74**	
				WET 46	**PASS**
				R Rating	**11**

Signed on behalf of FloorSlip Ltd:	A.I. Wylie	Name:	Andrew Wylie	Date:	09/03/21	Valid Until Date:	N/A

This test certificate is not valid or original if the embossed company stamp is not present

FloorSlip Ltd -. www.floorslip.co.uk
e:mail - info@floorslip.co.uk
Tel: 08719 152535 / 08713 155789

Registered Office - The Meridien, 4 Copthall House, Coventry, CV1 2FL Company number: 07757686
Please do NOT reply to this address as it is an unmonitored Address

FLOOR SLIP RESISTANCE TESTING CERTIFICATE

Testing Certificate Ref No: -

Continuation Sheet - ONE

Ref	Supplier	Surface	Ambient Temp (deg C)	Mean (Average) Reading	Pass / Fail